



TIE-IN VALVE MUST BE CLOSED AND REMAIN LOCKED. CITY TO PROVIDE LOCKING MECHANISM. VALVE WILL BE OPERATED BY CITY PERSONNEL ONLY.

**NOTE:**

THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL MATERIALS, ASSEMBLY, AND THE INSTALLATION OF THE DEVICE.

**TEMPORARY JUMPER CONNECTION**

CITY OF SANFORD

1999

FIG. 504A